

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO :

DATED :

It is certified that an inspection team headed by Dr. Mansukh Dobariya
 (Name of Officers with designation) from Health and Sanitary Department inspected the Girnar
 Public School, Puspkanj College Road Junagadh on _____ (date of inspection) and found
 that the Girnar Public School, Junagadh has safe drinking water Facilities for the students and
 members of staff of the institution and maintaining the hygienic sanitation condition in the school
 building & the campus as per norms prescribed by the Central / State / U.T.Govt.

The above is valid for a period of _____ year

Signature with Seal :

Dr. Dhruv

Name :

Dr. Mansukh Dobariya

Designation :

Medical Officer

Name & Address of the Office / Department :

Dr. Dhruv
 Medical Officer
 Urban Primary Health Center
 Shantashree

To

GIRNAR PUBLIC School
Junagadh.

(Name & Address Of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a Single pdf.



Laboratory In Charge,
District Laboratory,
G.W.S. & S.B.
"JAL BHAVAN" 2nd Floor,
Bilkha Road,
JUNAGADH - 362001
Phone : (0285)2652298



પ્રયોગશાળા ઇન્ચાર્જ,
જીલ્લા પ્રયોગશાળા,
ગુજરાત પા.પૂ. અને ગ.વ્ય.બોર્ડ,
"જલ ભવન", બીજો માળ બીલખા રોડ,
જુનાગઢ- ૩૬૨૦૦૧
ફોન : (૦૨૮૫) ૨૬૫૨૨૯૮
E-mail : junagadhlab@gmail.com

Test Report

Name & Address of Customer:-

GIRNAR PUBLIC SCHOOL

PUSHPKUNJ OPPOSITE HAJIYANI BAG
COLLEGE ROAD
JUNAGADH
DIST. - JUNAGADH

Customer Reference No.:

NIL/ DT - 18/04/2024

Sample Submitted by :

Sender

Date of Sample Receipt :

18-Apr-24

Analysis Starting Date :

18-Apr-24

Analysis Completion Date :

19-Apr-24

Discipline : Chemical Testing

Group : Water

Test Report No.:	14/2024-25	Date of Issue :	20-04-2024	
Sample ID :	JUCW - 14/04/2024	Mode of Sample:	0	
Main Source :	GROUND WATER	Source :	R O FILTER WATER (TUBE WELL 900 FT)	
Location :	IN SECOND FLOOR			
Village :	JUNAGADH	Habitation :	--	
Taluka :	JUNAGADH	District :	JUNAGADH	
Latitude :	0	Longitude :	0	
Kindly find herewith the Analytical Results.		Sample Type:	Drinking Water	
Sr. No.	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24 th Ed.2023), Method: 2120 C	1.04
2	Odour	-	IS 3025, 2018 (Second Revision) (Part-5)	Agreeable
3	Taste	-	IS 3025, 1984 (Reaffirmed 2012) (Part-8)	Agreeable
4	Turbidity	NTU	APHA (24 th Ed.2023), Method: 2130 B	0.74
5	pH at 25 ^o C	-	APHA (24 th Ed.2023) Method: 4500 H ⁺ B	7.52
6	Conductivity at 25 ^o C	μS/cm	APHA (24 th Ed.2023) Method: 2510 B	295
7	Total Dissolved Solids	mg/l	APHA (24 th Ed.2023) Method: 2540 C	190
8	Total Hardness (as CaCO ₃)	mg/l	APHA (24 th Ed.2023) Method: 2340 C	64
9	Calcium (as Ca ⁺²)	mg/l	APHA (24 th Ed.2023) Method: 3500 Ca ⁺² B	13
10	Magnesium (as Mg ⁺²)	mg/l	APHA (24 th Ed.2023) Method: 3500-Mg ⁺² B	8
11	Chloride (as Cl ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-Cl ⁻ B	40
12	Sulphate (as SO ₄ ⁻²)	mg/l	APHA (24 th Ed.2023) Method: 4500-SO ₄ ⁻² E	32
13	Nitrate (as NO ₃ ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-NO ₃ ⁻ B	9.27
14	Fluoride (as F ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-F ⁻ C	0.09
15	Total Alkalinity (as CaCO ₃)	mg/l	APHA (24 th Ed.2023) Method: 2320 B	44

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Name & Address Of Customer & details of Sample are Provided by the Customer.

Prepared & Checked By :

Technical Manager / Dy. Q.Mg.

Issued By:

(Ravi Pansuriya)
Quality Manager
Authorised Signatory

End of the Test Report

O.W.No. DLJU/JND/C. Report/ 199 /of 2024, Dt. 20 / 4 /2024.

Second Floor, "Jalbhavan", Bilkha Road, Junagadh-362001

E-mail: junagadhlab@gmail.com

P.O. (0285) 2652298,

IS-10500:2012 (2nd Revision)

Sr. No.	Parameter	Unit	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
			Max.	Max.
1	Colour	Hazen	5	15
2	Odour	-	Agreeable	Agreeable
3	Taste	-	Agreeable	Agreeable
4	Turbidity	NTU	1	5
5	pH at 25 ⁰ C	-	6.5 to 8.5	No relaxation
6	Conductivity at 25 ⁰ C	μS/cm	-	-
7	Total Dissolved Solids	mg/l	500	2000
8	Total Hardness (as CaCO ₃)	mg/l	200	600
9	Calcium (as Ca)	mg/l	75	200
10	Magnesium (as Mg)	mg/l	30	100
11	Chloride (as Cl)	mg/l	250	1000
12	Sulphate (as SO ₄)	mg/l	200	400
13	Nitrate (as NO ₃)	mg/l	45	No relaxation
14	Fluoride (as F)	mg/l	1	1.5
15	Total Alkalinity (as CaCO ₃)	mg/l	200	600